

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0801:214 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Radionics, Div. of Detection Systems, 130 Perinton Parkway, Fairport NY 14450-9199
Contact: Frank Mioduszewski *(585) 223-4060 Fax (585) 421-4263

DESIGN: Models D9068 and D9068LC digital alarm communicator transmitter. Model D9068 and D9068LC are identical except that Model D9068 is comprised of Model D9068LC and Model AE203R enclosure. Units are intended for remote station and central station applications. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12/24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed fire alarm control units.

*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager